



CLEARWATER FIRE & RESCUE
DIVISION OF FIRE PREVENTION SERVICES

1140 Court St., Clearwater, Florida 33756 Phone: 727-562-4334

Food Tent Vendor - Inspection Checklist

Business Name: _____ Date: _____

Business Address: _____ City/State/Zip: _____

Owner's Name: _____

Owner's Phone #: _____ Email: _____

Required Fire Safety Components

LPG Tanks properly spaced and secured in upright position: Yes No N/A

Portable Generator properly spaced and topped off with fuel: Yes No N/A

Portable Extinguisher: 10BC minimum Yes No Inspection Date: _____

Portable Extinguisher: "K" Class: NA Yes No Inspection Date: _____

FFPC 8th Edition, NFPA 1 & 101 2021 edition

1: 50.1.3 Cooking equipment used in fixed, mobile, or temporary concessions, such as trucks, buses, trailers, pavilions, tents, or any form of roofed enclosure, shall comply with NFPA 96. [96:1.1.3]

1:50.8.3.1 Temporary cooking operations conducted in tents shall comply with NFPA 102 and Chapter 25. [96:17.3.1]

Violations

- Failure to have **proper mounting/spacing** of propane tanks
- Failure to have **portable generator** spaced properly
- Failure to **properly store flammable liquids**
- Missing/inoperable/inaccessible, or not serviced **fire extinguishers**

NFPA Code References

LP(Propane)/CNG(Natural Gas)

1: 50.8.7.7.6.1 Cylinders in storage shall be located to minimize exposure to excessive temperature rises, physical damage, or tampering.

1: 50.8.7.1.1 Cylinders shall be secured in an upright position to prevent tipping over.

101: 11.11.6.1.3 Containers for liquefied petroleum gases shall be installed not less than 60 in. (1525 mm) from any tent and shall be in accordance with the provisions of NFPA 58.

Generator

1: 50.8.5.4.3 Internal combustion engine power sources shall be positioned so that the exhaust complies with the following: 1) Located at least 12ft from openings, air intakes, and means of egress. 2) In a position away from any building. 3) In a position pointed away from any mobile or temporary cooking operation.

Fire Extinguishers

1: 50.4.11.2 Class K fire extinguishers shall be provided for cooking appliance hazards that involve combustible cooking media (vegetable oils and animal oils and fats). [96:10.9.2]

1: 50.4.11.1 Portable fire extinguishers shall be selected and installed in kitchen cooking areas in accordance with Section 13.6 and shall be specifically listed for such use.

1: 50.5.7.5 A minimum of one 2A:10BC portable fire extinguisher shall be provided when a generator or other fuel fired appliance is used.

FFPC 8th Edition, NFPA 1 & 101 2021 edition

1: 50.1.3 Cooking equipment used in fixed, mobile, or temporary concessions, such as trucks, buses, trailers, pavilions, tents, or any form of roofed enclosure, shall comply with NFPA 96. [96:1.1.3]

1:50.8.3.1 Temporary cooking operations conducted in tents shall comply with NFPA 102 and Chapter 25. [96:17.3.1]